

Improving the automatic inversion of digital ISIS-2 ionogram reflection traces into topside vertical electron-density profiles

R.F. Benson, V. Truhlik, X. Huang, Y. Wang, and D. Bilitza

The topside-sounders on the four satellites of the International Satellites for Ionospheric Studies (ISIS) program were designed as analog systems. The resulting ionograms were displayed on 35-mm film for analysis by visual inspection. Each of these satellites, launched between 1962 and 1971, produced data for 10 to 20 years. A number of the original telemetry tapes from this large data set have been converted directly into digital records. Software, known as the TOPside Ionogram Scalar with True-height (TOPIST) algorithm has been produced that enables the automatic inversion of ISIS-2 ionogram reflection traces into topside vertical electron-density profiles $N_e(h)$. More than $\frac{1}{2}$ million digital Alouette/ISIS topside ionograms have been produced and over 300,000 are from ISIS 2. Many of these ISIS-2 ionograms correspond to a passive mode of operation for the detection of natural radio emissions and thus do not contain ionospheric reflection traces. TOPIST, however, is not able to produce $N_e(h)$ profiles from all of the ISIS-2 ionograms with reflection traces because some of them did not contain frequency information. This information was missing due to difficulties encountered during the analog-to-digital conversion process in the detection of the ionogram frame-sync pulse and/or the frequency markers. Of the many digital topside ionograms that TOPIST was able to process, over 200 were found where direct comparisons could be made with $N_e(h)$ profiles that were produced by manual scaling in the early days of the ISIS program. While many of these comparisons indicated excellent agreement ($<10\%$ average difference over the entire profile) there were also many cases with large differences (more than a factor of two). Here we will report on two approaches to improve the automatic inversion process: (1) improve the quality of the digital ionogram database by remedying the missing frequency-information problem when possible, and (2) using the above-mentioned comparisons as teaching examples of how to improve the original TOPIST software.